



Three Phase Squirrel Cage Induction Motor

Motor type TE Q3H 160L4B

Electrical Data

RATED VALUES							STARTING VALUES				BREAKDOWN	EFFICIENCY			Eff. CLASS
VOLTAGE V	POWER		SPEED	CURRENT	TORQUE	Cos φ	CURRENT IA/IN		TORQUE MA/MN		TORQUE Mk/Mn Nm	%			IEC 60034-30-1
	kW	Hz	rpm	A	Nm	4/4	Y	D	Y	D	Nm	4/4	3/4	2/4	IE
400/690	15	50	1477	30,85/17,8	97,1	0,76	2,6	7,833	0,9	2,84	3,3	IE3-92,1%	92	90,8	IE3
460/795	17,3	60	1773	28,2/16,3	92,9	0,82	2,5	7598	0,9	2,7	3,2	-	-	-	

Mechanical Data

Bearing DE	6309-ZZ	Color	RAL 7031
Bearing NDE	6209-ZZ	Motor protection	PTC
Lubricants	Shell Gadus S5 V220-2	Method of cooling	IC 411 (TEFC)
Condensation drain hole	No	Terminal box position	Top
External earthing terminal	Yes	Material of terminal box	Aluminium
Vibration class	A	Terminal plate thread	M6
Insulation class	F	Cable gland	1xM32
Duty type	S1	Clamping range	18-25 mm
Direction of rotation	Clockwise	Mounting type	IM B3
Housing material	Aluminium		
Type of balancing	Half Key		

Environmental Data

Others

Ambient Temperature	-20/+40 °C	Type of protection	IP55
Altitude above sea level	1000 m	Sound Pressure Level 50/60Hz dBA	62
		Moment of Inertia (kg.mm ²)	0,090053
		Standard	IEC 60034-1
		Weight (Kg)	101

***Lubrication:**

Closed type (ZZ) roller bearings are being used.

These types of roller bearings do not require maintenance since they are lubricated with the type of lubricant specified by the manufacturer.

Roller bearings should be replaced after 20,000 hours of operation (approx. 2-5 years of use) due to the specified operation temperature, vibration level and shaft loads.